

Facility Summary in SILVER BOW County in the City of ANACONDA

Location: FAIRMONT RV PARK AND CAMPGROUND LLC
1700 FAIRMONT RD
ANACONDA, MT 59711 SILVER BOW

Sys Fac ID: 56-13976
Last Inspected On: 9/20/2013
Operating Permit Renewal Date: 11/1/2016

Contact: Nancy or Kevin Johnson, (406) 797-3505

Owners/Operators: Fairmont RV Park & Campground LLC, Owner (406)-209-1794 1700 FAIRMONT RD
ANACONDA MT 59711-9419

Kevin Johnson, UST Class A Operator
Nancy Johnson, UST Class A Operator
Jeana Johnson, UST Class B Operator
Kevin Johnson, UST Class B Operator
Nancy Johnson, UST Class B Operator
Shelia Johnson, UST Class B Operator
Caroline Thomer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	15	4/1/2000	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4187			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Continuous Interstitial Monitor	Deferred	
3,000					
3	15	4/1/2000	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4188			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Deferred	
3,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: CENEX ZIP TRIP #73
848 W PARK ST
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-00386

Last Inspected On: 11/5/2013

Operating Permit Renewal Date: 11/13/2016

Contact: Rick Bates, (509) 535-7701

Owners/Operators: CHS Inc - Spokane Valley, Owner/Operator (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216

Roy Morris, UST Class A Operator
Isaac Durnford, UST Class B Operator
Mitchell Kilmer, UST Class B Operator
Terri Stringer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	17	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4425			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					
6	17	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4426			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000					
7	17	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4427			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
5,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: ACADIA MONTANA
55 BASIN CREEK RD
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-00458
Last Inspected On: 4/9/2013
Operating Permit Renewal Date: 9/21/2016

Contact: Leon Huizinga, (406) 496-6329

Owners/Operators: Kids Behavioral Health, Owner (406)-494-4183 55 BASIN CREEK RD
BUTTE MT 59701
Leon Huizinga, Operator (406)-496-6329 55 BASIN CREEK RD
BUTTE MT 59701-9704
Leon Huizinga, UST Class A Operator
Leon Huizinga, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	28	6/22/1987	Fiberglass Reinforced Plastic	Copper	Flapper Valve (Auto Shutoff)
3974		9/18/2013	None	Secondary Containment Chase	Yes
Currently in Use			Auto Dialer	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Not Listed	
2,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY SUPER STOP 5
901 E FRONT ST
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-00942

Last Inspected On: 6/6/2013

Operating Permit Renewal Date: 6/12/2016

Contact: David Sutey, (406) 494-2305

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE
BUTTE MT 59701-3553

Louie Sutey, UST Class A Operator
Jack Hook, UST Class B Operator
Linda Otonicar, UST Class B Operator
Jack Hook, UST Class B Global Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	21	8/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2059			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					
2	21	8/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2060			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					
3	21	8/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2061			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: MDOT BUTTE DISTRICT HEADQUARTERS
3751 WYNNE AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-01062

Last Inspected On: 2/26/2013

Operating Permit Renewal Date: 7/14/2016

Contact: Joe Radonich, (406) 444-9204

Owners/Operators: MDOT Helena, Owner Joseph J Radonich, Operator Jeff Gleason, UST Class A Operator Walt Kerttula, UST Class A Operator Mike Murolo, UST Class A Operator Joe Radonich, UST Class A Operator Roy Beckman, UST Class B Operator Donald Serich, UST Class B Operator Lorrin Wallace, UST Class B Operator Joe Radonich, UST Class B Global Operator	(406)-444-6200 (406)-444-9204	KIM JANZEN PO BOX 201001 HELENA MT 59620-1001 MDT DEADHEAD HELENA MT 59620-0901
---	--------------------------------------	--

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	21	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2937			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
10,000					
9	21	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2938			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
10,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: MOUNT MORIAH CEMETERY ASSOCIATION
2415 S MONTANA ST
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-01705

Last Inspected On: 7/23/2013

Operating Permit Renewal Date: 10/9/2016

Contact: Edwin J Zimpel III, (406) 782-1778

Owners/Operators: Mount Moriah Cemetery Association, Owner

(406)-782-1778

2415 S MONTANA ST
BUTTE MT 59701-3047

Carolyn Goody, UST Class A Operator

Carolyn Goody, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	19	7/1/1996	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1720			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		7/23/2013	Manual Tank Gauging	Deferred	
300					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: SHEAS AUTO REPAIR
910 S MONTANA ST
BUTTE, MT 59701 SILVER BOW

Contact: Jamey Shea, (406) 723-7306

Sys Fac ID: 47-01835
Last Inspected On: 2/10/2014
Operating Permit Renewal Date: 4/20/2017

Owners/Operators: Bigheads Inc, Owner (406)-723-7306 624 N HENRY AVE
BUTTE MT 59701-2838
Catherine Shea, UST Class A Operator
Paul Shea, UST Class A Operator
Jake Perusich, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	17	2/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3959			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000			Gilbarco EMC Basic , Gilbarco		
8	17	2/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3960			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000			Gilbarco EMC Basic , Gilbarco		
9	17	2/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3961			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: BUTTE SCHOOL DIST 1 BUS BARN
1220 E FRONT ST
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-01980

Last Inspected On: 12/9/2013

Operating Permit Renewal Date: 1/31/2017

Contact: Mel Rauch, (406) 496-2185

Owners/Operators: School Dist 1 Butte, Owner (406)-496-2185 1220 E FRONT ST
BUTTE MT 59701-2936
Leonard Diaz, UST Class A Operator
Jed Johnson, UST Class A Operator
Leonard Diaz, UST Class B Operator
Jed Johnson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1892			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Deferred	
10,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: LAVELLE EQUIPMENT REPAIR
200 LA SALLE ST
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-02689

Last Inspected On: 12/3/2014

Operating Permit Renewal Date:

Contact: William Lavelle, (406) 490-4321

Owners/Operators: Lavelle Equipment & Repair LLC, Owner (406)-490-4321 200 LASALLE
BUTTE MT 59701
William P Lavelle IV, Operator (406)-490-4321 200 LASALLE
BUTTE MT 59701
William P Lavelle IV, UST Class A Operator
William P Lavelle IV, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	12/1/1991	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
384			Impressed Current	none	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Diesel		12/3/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
10,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: CENEX ZIP TRIP #72
2801 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-05148

Last Inspected On: 11/5/2014

Operating Permit Renewal Date: 12/26/2017

Contact: Rick Bates, (509) 535-7701

Owners/Operators: CHS Inc - Spokane Valley, Owner/Operator (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216

Sean Hurley, UST Class A Operator
Deb Morris, UST Class A Operator
Roy Morris, UST Class A Operator
Isaac Durnford, UST Class B Operator
Mitchell Kilmer, UST Class B Operator
Deb Morris, UST Class B Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	25	3/19/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1709			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000					
2	25	3/19/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1710			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000					
3	25	3/19/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1711			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
6,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: CENEX ZIP TRIP #72
2801 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-05148
Last Inspected On: 11/5/2014
Operating Permit Renewal Date: 12/26/2017

Contact: Rick Bates, (509) 535-7701

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	25	3/19/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1707			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
12,000					
9	25	3/19/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1708			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
12,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: LISACS SOUTHSIDE EXXON
2544 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-05202

Last Inspected On: 5/12/2014

Operating Permit Renewal Date: 8/19/2017

Contact: Edward Lisac, (406) 494-7056

Owners/Operators: Edward Lisac, Owner (406)-494-7056 2544 HARRISON AVE
BUTTE MT 59701-6055
Nadene Lisac, UST Class A Operator
Nadene Lisac, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	25	3/8/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
1547			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	25	3/8/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
1546			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	20	6/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1549			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		6/17/2008	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	20	6/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1548			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/17/2008	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: HOLLOW CONSTRUCTION
404 W GREENWOOD AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-05359

Last Inspected On: 1/9/2015

Operating Permit Renewal Date:

Contact: William J Hollow, (406) 782-6033

Owners/Operators: Hollow Contracting, Owner (406)-782-6033 404 W GREENWOOD AVE
BUTTE MT 59701-2898
Susan Lasher, UST Class A Operator
Susan Lasher, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4162			None	Double-Walled	Yes
Temporarily Out of Use		5/1/2009	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
15,000					
3	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4163			None	Double-Walled	Yes
Temporarily Out of Use		5/1/2009	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000					
4	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4164			None	Double-Walled	Yes
Temporarily Out of Use		5/1/2009	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: SUNKEN TREASURE
2900 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-05772

Last Inspected On: 5/16/2014

Operating Permit Renewal Date: 8/2/2017

Contact: Jon Dehler, (406) 494-2402

Owners/Operators: JD & JD LLC, Owner (406)-259-8857 200 REGAL ST
BILLINGS MT 59101-3133

Bobbie Goodenow, UST Class A Operator

Marco Kurilich, UST Class A Operator

Bobbie Goodenow, UST Class B Operator

Marco Kurilich, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	37	11/14/1978	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1369			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	43	11/13/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1370			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	43	11/13/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1371			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: SUNKEN TREASURE
2900 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-05772

Last Inspected On: 5/16/2014

Operating Permit Renewal Date: 8/2/2017

Contact: Jon Dehler, (406) 494-2402

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	43	11/13/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1372			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: ST JAMES HEALTHCARE INC
400 S CLARK ST
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-06924
Last Inspected On: 9/10/2013
Operating Permit Renewal Date: 12/5/2016

Contact: Dave Fawcett, (406) 723-2500

Owners/Operators: St James Healthcare Inc, Owner (406)-723-2747 400 S CLARK ST
BUTTE MT 59701-2328
David Fawcett, UST Class A Operator
David Palmer, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	14	5/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4449			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
15,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY SUPER STOP 1
3501 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-07932

Last Inspected On: 6/6/2013

Operating Permit Renewal Date: 11/13/2016

Contact: David Sutey, (406) 494-2305

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE
BUTTE MT 59701-3553

Louie Sutey, UST Class A Operator
Cindy Beck, UST Class B Operator
Jack Hook, UST Class B Operator
Stacey Smith, UST Class B Operator
Carrie Taylor, UST Class B Operator
Jack Hook, UST Class B Global Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	25	4/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2062			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable
Gasoline		2/7/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
14,783		6/23/2009		MLLD Line Tightness Testing	
8	25	4/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2065			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable
Diesel		2/7/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,929		6/23/2009		MLLD Line Tightness Testing	
9	25	4/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2066			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable
Diesel		2/7/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,929		6/23/2009		MLLD Line Tightness Testing	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY SUPER STOP 1
3501 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-07932

Last Inspected On: 6/6/2013

Operating Permit Renewal Date: 11/13/2016

Contact: David Sutey, (406) 494-2305

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	25	4/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2063			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable
Gasoline		2/7/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
11,627		6/23/2009		MLLD Line Tightness Testing	
11	25	4/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2064			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable
Gasoline		2/7/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
11,627		6/23/2009		MLLD Line Tightness Testing	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY SUPER STOP 4
2610 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-07934

Last Inspected On: 6/6/2013

Operating Permit Renewal Date: 6/20/2016

Contact: David Sutey, (406) 494-2305

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE
BUTTE MT 59701-3553

Jack Hook, UST Class A Operator
Louie Sutey, UST Class A Operator
Jack Hook, UST Class B Operator
Rebecca Hook, UST Class B Operator
Michael Townsend, UST Class B Operator
Jack Hook, UST Class B Global Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	25	3/13/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2067			None	None	Yes
Currently in Use		3/13/2000	Mechanical Line Leak Detector	Not Listed	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
11,627		6/3/2013			
6	25	3/13/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2068			None	None	Yes
Currently in Use		3/13/2000	Mechanical Line Leak Detector	Not Listed	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
11,627		6/3/2013			
7	25	3/13/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2069			None	None	Yes
Currently in Use		3/13/2000	Mechanical Line Leak Detector	Not Listed	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
11,627		6/3/2013			

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY SUPER STOP 2
1900 S MONTANA ST
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-07935

Last Inspected On: 6/7/2013

Operating Permit Renewal Date: 6/12/2016

Contact: Dave Sutey, (406) 782-5661

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE
BUTTE MT 59701-3553

Jack Hook, UST Class A Operator
Louie Sutey, UST Class A Operator
Jack Hook, UST Class B Operator
Patsy Lingenfelter, UST Class B Operator
Christopher Otonicar, UST Class B Operator
Sam Spetter, UST Class B Operator
Jack Hook, UST Class B Global Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	26	5/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2070			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
11,627		6/5/2013			
5	26	5/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2071			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
11,627		6/5/2013			
6	26	5/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2072			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
11,627		6/5/2013			

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY SUPER STOP 6
2401 CONTINENTAL DR
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-07936

Last Inspected On: 6/7/2013

Operating Permit Renewal Date: 11/13/2016

Contact: David Sutey, (406) 494-2305

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE
BUTTE MT 59701-3553

Ken Beck, UST Class A Operator
Louie Sutey, UST Class A Operator
Ken Beck, UST Class B Operator
Jack Hook, UST Class B Operator
Marianne Taylor, UST Class B Operator
Jack Hook, UST Class B Global Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	47	5/7/1968	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2073		7/23/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		2/8/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		8/26/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	47	5/7/1968	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2074		7/23/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/8/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		8/26/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	42	5/7/1973	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2075		7/23/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/8/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		8/26/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: BUTTE SILVER BOW MAINTENANCE CENTER
1700 CIVIC CENTER RD
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-08477

Last Inspected On: 4/9/2013

Operating Permit Renewal Date: 6/9/2016

Contact: Rick Gelling, (406) 497-6569

Owners/Operators: Butte Silver Bow County, Owner (406)-497-6569 1700 CIVIC CENTER RD
BUTTE MT 59701-4857

Todd Skartved, UST Class A Operator
John Stajcar, UST Class A Operator
Todd Skartved, UST Class B Global Operator
John Stajcar, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	19	1/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
511		9/19/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
15,000					
7	19	1/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
512		9/19/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
15,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 1
1370 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-08679

Last Inspected On: 2/2/2015

Operating Permit Renewal Date: 5/31/2018

Contact: Roger Hovis, (406) 782-4442

Owners/Operators: Town Pump Inc, Owner (406)-497-6947 PO BOX 6000
BUTTE MT 59702-2534

Trent Biggers, UST Class A Operator
Daniel Sampson, UST Class A Operator
Trent Biggers, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	7/28/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2621			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	27	4/11/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2620			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	29	4/11/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2619			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 1
1370 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-08679

Last Inspected On: 2/2/2015

Operating Permit Renewal Date: 5/31/2018

Contact: Roger Hovis, (406) 782-4442

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	27	4/11/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2618			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 2
531 S MONTANA ST
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-08680

Last Inspected On: 2/4/2015

Operating Permit Renewal Date: 2/9/2018

Contact: Kevin Kenneally, (406) 497-6700

Owners/Operators: Major Enterprises of Butte Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	30	9/1/1985	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2622			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		5/7/2006	TLS-350/Gilbarco EMC , Veeder Root		
2	30	9/1/1985	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2623			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		5/7/2006	TLS-350/Gilbarco EMC , Veeder Root		
3	27	9/1/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2624			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		5/7/2006	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 3
2328 S MONTANA ST
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-08682

Last Inspected On: 2/4/2015

Operating Permit Renewal Date: 2/9/2018

Contact: Kevin Kenneally, (406) 782-6758

Owners/Operators: Montana Town Pump Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	25	10/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2626			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/5/2012	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
4	25	10/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2627			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/5/2012	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	25	10/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2628			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/5/2012	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 3
2328 S MONTANA ST
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-08682

Last Inspected On: 2/4/2015

Operating Permit Renewal Date: 2/9/2018

Contact: Kevin Kenneally, (406) 782-6758

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	34	4/11/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2625			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/7/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 8
2001 DEWEY BLVD
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-08686
Last Inspected On: 2/4/2015
Operating Permit Renewal Date: 2/9/2018

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: U Pump Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000

Trent Biggers, UST Class A Operator
Scot Gramm, UST Class A Operator
Trent Biggers, UST Class B Global Operator
Scot Gramm, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	34	10/1/1981	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2629			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
30,000			TLS-350/Gilbarco EMC , Veeder Root		
2	34	10/1/1981	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4265			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
30,000			TLS-350/Gilbarco EMC , Veeder Root		
3	39	1/1/1977	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2631			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 8
2001 DEWEY BLVD
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-08686

Last Inspected On: 2/4/2015

Operating Permit Renewal Date: 2/9/2018

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	34	10/1/1981	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2632			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 10
901 N EXCELSIOR AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-08687

Last Inspected On: 2/4/2015

Operating Permit Renewal Date: 2/9/2018

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Excel Town Pump Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator
Brad Nelsen, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	44	4/12/1971	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2633			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	44	4/12/1971	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2634			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY #16
4701 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-10657
Last Inspected On: 6/27/2013
Operating Permit Renewal Date: 7/10/2016

Contact: Linda Sutey, (406) 494-2305

Owners/Operators: Sutey Oil Co Inc, Owner/Operator (406)-494-2305 2000 HOLMES AVE
BUTTE MT 59701-3553

Joe Benski, UST Class A Operator
Adriana Rigney, UST Class A Operator
Joe Benski, UST Class B Operator
Mark Hodges, UST Class B Operator
Adriana Rigney, UST Class B Operator
Jack Hook, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	28	11/1/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1921			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/26/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		6/5/2013			
2	28	11/1/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1922			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/26/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		6/5/2013			
3	28	11/1/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1923			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/26/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		6/5/2013			

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY #16
4701 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-10657
Last Inspected On: 6/27/2013
Operating Permit Renewal Date: 7/10/2016

Contact: Linda Sutey, (406) 494-2305

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	28	11/1/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1924			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/26/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		6/5/2013			

Facility Summary in SILVER BOW County in the City of BUTTE

Location: SILVER BOW COUNTY PUBLIC WORKS
BROWNS GULCH
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-13157

Last Inspected On: 4/9/2013

Operating Permit Renewal Date: 6/9/2016

Contact: Rick Gelling, (406) 497-6569

Owners/Operators: Silver Bow County Browns Gulch Landfill, Owner

(406)-497-6521

RICK GELLING
126 W GRANITE ST
BUTTE MT 59701-9216

Todd Skartved, UST Class A Operator

John Stajcar, UST Class A Operator

Todd Skartved, UST Class B Global Operator

John Stajcar, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4465			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Deferred	
12,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC ROCKER
1000 GRIZZLY TRL
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-13173

Last Inspected On: 2/2/2015

Operating Permit Renewal Date: 5/31/2018

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Town Pump of Rocker Inc, Owner (406)-497-6700 600 S MAIN
BUTTE MT 59701-6000
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2644			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	22	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2645			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
3	22	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2635			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
4	22	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2641			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC ROCKER
1000 GRIZZLY TRL
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-13173
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 5/31/2018

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	22	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2642			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
6	22	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2643			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
7	22	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2639			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
8	22	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2640			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
9	22	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2638			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC ROCKER
1000 GRIZZLY TRL
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-13173

Last Inspected On: 2/2/2015

Operating Permit Renewal Date: 5/31/2018

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	22	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2637			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
11	22	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2636			None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
12	16	6/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4103			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: RD'S QUICK FUEL
16 E DEWEY BLVD
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-13531

Last Inspected On: 9/3/2013

Operating Permit Renewal Date: 12/5/2016

Contact: Roy Morris, (406) 491-4255

Owners/Operators: Morris Marketing Co Inc, Owner (406)-782-4255 PO BOX 3839
BUTTE MT 59702-3839
City Service Valcon LLC, Operator (406)-751-4640 PO BOX 1
KALISPELL MT 59903-0001
Roy Morris, UST Class A Operator
Mitchell Kilmer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	21	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1712			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
20,000		8/20/2013			
2	21	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1713			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line	
20,000		8/20/2013		Tightness Testing	
3	21	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1714			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line	
20,000		8/20/2013		Tightness Testing	
4	21	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1715			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line	
10,000		8/20/2013		Tightness Testing	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: RD'S QUICK FUEL
16 E DEWEY BLVD
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-13531
Last Inspected On: 9/3/2013
Operating Permit Renewal Date: 12/5/2016

Contact: Roy Morris, (406) 491-4255

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	21	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1716			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line	
				Tightness Testing	
10,000		8/20/2013			
6	21	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1717			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line	
				Tightness Testing	
10,000		8/20/2013			
7	21	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1718			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line	
				Tightness Testing	
10,000		8/20/2013			

Facility Summary in SILVER BOW County in the City of BUTTE

Location: MONTANA RESOURCES INC
600 SHIELDS AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-13549

Last Inspected On: 11/11/2014

Operating Permit Renewal Date: 3/5/2018

Contact: Robert Solari, (406) 723-4081

Owners/Operators: Montana Resources, Owner (406)-723-4081 600 SHIELDS AVE
BUTTE MT 59701-2799
Thomas Dale, UST Class A Operator
Thomas Dale, UST Class B Operator
Daniel Lorengo, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	18	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1687		8/20/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Waste Oil			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
6,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: BUTTE AVIATION INC
4602 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 47-13713

Last Inspected On: 11/26/2001

Operating Permit Renewal Date:

Contact: Dr Gene Hughes, (406) 494-6694

Owners/Operators: Butte Aviation Inc, Owner

(406)-494-6694

4602 HARRISON AVE
BUTTE MT 59701-6965

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	12/1/1995	Cathodically Protected Steel	Steel	
4663			None	None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Aviation Gas			Manual Tank Gauging	Deferred	
100					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 4
3700 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 56-13911

Last Inspected On: 7/1/2015

Operating Permit Renewal Date: 10/14/2018

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Bonner Holdings LLC, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	16	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4022		8/13/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	16	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4023		8/13/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	16	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4024		8/13/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	16	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4025		8/13/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 4
3700 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 56-13911

Last Inspected On: 7/1/2015

Operating Permit Renewal Date: 10/14/2018

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	16	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4026		8/13/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	16	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4294		8/13/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: NORTHWEST PETROLEUM FACILITY
28 DEWEY BLVD
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 56-14033

Last Inspected On: 7/1/2015

Operating Permit Renewal Date: 10/14/2018

Contact: Kevin Kenneally, (406) 496-6062

Owners/Operators: Northwest Petroleum Co, Owner/Operator

(406)-497-6700

PO BOX 6000

BUTTE MT 59702-6000

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	13	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4639			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	13	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4640			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	13	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4641			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	13	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4642			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: NORTHWEST PETROLEUM FACILITY
28 DEWEY BLVD
BUTTE, MT 59701 SILVER BOW
Contact: Kevin Kenneally, (406) 496-6062

Sys Fac ID: 56-14033
Last Inspected On: 7/1/2015
Operating Permit Renewal Date: 10/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	13	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4643			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	13	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4644			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	13	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4645			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	13	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4646			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: QWEST BUTTE MAIN CENTRAL OFFICE
200 W BROADWAY ST
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 56-14034

Last Inspected On: 12/31/2013

Operating Permit Renewal Date: 4/18/2017

Contact: Kevin Robison, (801) 237-3006

Owners/Operators: Qwest Corporation, Owner	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111
Qwest Corporation, Operator	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111
Kevin Robison, UST Class A Operator		
Kevin Robison, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	13	10/2/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4732		12/18/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,500			TLS-300 , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: DETENTION CENTER
155 W QUARTZ ST
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 56-14119

Last Inspected On: 3/18/2014

Operating Permit Renewal Date: 5/27/2017

Contact: Gary Lean, (406) 497-6401

Owners/Operators: Butte Silver Bow County, Owner (406)-497-6569 1700 CIVIC CENTER RD
BUTTE MT 59701-4857
Jerome McCarthy, Operator BUTTE DETENTION CENTER
155 W QUARTZ ST
BUTTE MT 59701-9200
Jed Johnson, UST Class A Operator
John Stajcar, UST Class A Operator
Jed Johnson, UST Class B Global Operator
John Stajcar, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	11	1/31/2005	Steel Clad	Flexible Plastic	High Level Alarm
5006		3/12/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
1,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: Three Bears Alaska
45 THREE BEARS DR
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 60-15058
Last Inspected On: 8/8/2013
Operating Permit Renewal Date: 1/9/2017

Contact: David Weisz, (406) 494-7547

Owners/Operators: THREE BEARS ALASKA, Owner (907)-883-4324 PO BOX 189
TOK AK 99780-0189
Carla Caudy, UST Class A Operator
Carla Caudy, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	08	4/24/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5103			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
17,000					
2	08	4/24/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5104			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: FED EX DISTRIBUTION
119771 RICK JONES WAY
BUTTE, MT 59750 SILVER BOW

Sys Fac ID: 60-15178

Last Inspected On: 2/6/2015

Operating Permit Renewal Date: 4/12/2018

Contact: Greg Peters, (406) 782-4176

Owners/Operators: Arc Febttmt 001 LLC, Owner (215)-449-3600 200 DRYDEN ROAD SUITE 1100
DRESHER PA 19025
Greg Peters, Operator (406)-782-4176 119771 RICK JONES WAY
BUTTE MT 59701
Chong Lee, UST Class A Operator
Greg Peters, UST Class A Operator
Greg Peters, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	04	3/1/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5286			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		8/12/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP BUTTE #5
2305 CONTINENTAL DIVIDE
BUTTE, MT 59701 SILVER BOW

Sys Fac ID: 60-15187

Last Inspected On: 2/2/2015

Operating Permit Renewal Date: 6/11/2018

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Town Pump of Northwest Missoula Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Town Pump Inc, Operator (406)-497-6947 PO BOX 6000
BUTTE MT 59702-2534
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	04	11/1/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5310			Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
20,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
2	04	11/1/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5311			Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
3	04	11/1/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5312			Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in SILVER BOW County in the City of MELROSE

Location: MELROSE BAR SERVICE STATION POST OFFICE
110 MAIN ST
MELROSE, MT 59743 SILVER BOW

Sys Fac ID: 47-07486

Last Inspected On: 1/6/2015

Operating Permit Renewal Date: 3/3/2018

Contact: Burr Lively, (406) 835-2711

Owners/Operators: Lively Inc, Owner (406)-835-2721 PO BOX 96
MELROSE MT 59743-0096
Lee Lively, UST Class A Operator
Lee Lively, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	32	5/8/1983	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4054			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/6/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	32	5/8/1983	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4055			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		1/6/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of ROCKER

Location: ROCKER FLYING J
112000 ROCKER INTERCHANGE
ROCKER, MT 59701 SILVER BOW

Sys Fac ID: 47-09893

Last Inspected On: 2/4/2015

Operating Permit Renewal Date: 2/9/2018

Contact: Gary Dietz, (406) 723-4325

Owners/Operators: Montana Innovations LLC, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
16			Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5302			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
30,000		9/6/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
17			Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5303			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
30,000		9/6/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
18			Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5304			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
30,000		9/6/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of ROCKER

Location: ROCKER FLYING J
112000 ROCKER INTERCHANGE
ROCKER, MT 59701 SILVER BOW
Contact: Gary Dietz, (406) 723-4325

Sys Fac ID: 47-09893
Last Inspected On: 2/4/2015
Operating Permit Renewal Date: 2/9/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
19			Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5305			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
30,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
20			Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5306			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
21			Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5307			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
22			Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5308			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	